

ROUSES POINT WATER SYSTEM

COMPLIANCE NOTICE

June 30, 2009

The Village of Rouses Point; with the assistance of the CCHD, NYSDOH and the Village's Engineer have been working together to bring the Village of Rouses Point into compliance for Total Trihalomethanes and Haloacetic Acids. As a result, the Village requested and has been issued a permit for a pilot chlorination plan; this plan will allow the Village to chlorinate at 2 locations, the water treatment plant and at the water storage tank. Implementation of the pilot chlorination began March 2, 2009. The public should be advised that each time the Village makes changes; it could take 4 quarters of sampling or 1 year of testing to acquire our new annual running average; and to see if that change brings the Village into compliance. The Village has conducted monthly sampling to monitor changes since the implementation of the pilot chlorination plan. All samples collected since the implementation of the pilot chlorination have been below the maximum contamination levels for both Total Trihalomethanes and Haloacetic Acids.

The first quarter of 2009 test result for Total Trihalomethanes was 54.6; which is below the MCL (maximum contamination level) of 80; however our running average remained above the MCL.

The first quarter of 2009 test result for Haloacetic Acids was 56; which is below the MCL (maximum contamination level) of 60; however our running average remained above the MCL.

The second quarter test result for Total Trihalomethanes is 64.9 which is below the MCL of 80; our annual running average is 76.65 which is now below the MCL of 80.

The Village of Rouses Point is now in compliance for Total Trihalomethanes.

The second quarter test result for Haloacetic Acids is 37.7; which is below the MCL of 60; our annual running average is 55.25; which is now below the MCL of 60.

The Village of Rouses Point is now in compliance for Haloacetic Acids.

If there are any questions please contact the Rouses Point water plant at 297-5502 ext. 313 or you may obtain information at the Clinton County web site at: www.clintoncountygov.com

Gary A. Molinski
Chief Water Plant Operator